

# Certificate of Compliance

**Certificate:** 2509560

**Master Contract:** 190952

**Project:** 2509560

**Date Issued:** May 21, 2012

**Issued to:** QUADRITALIA SrL  
Via Mattei 6/10  
36040 Brendola (VI)  
ITALY  
Attention: Mr. G. Orani

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only*



**Issued by:** Giovanni Vertechy  
*Giovanni Vertechy*

## **PRODUCTS**

3211-11 INDUSTRIAL CONTROL EQUIPMENT – Enclosures for electrical equipment

3211-91 INDUSTRIAL CONTROL EQUIPMENT – Enclosures for electrical equipment – Certified to US Requirements

Industrial Control Panel Enclosures, Series OK K (disassembled, supplied as a kit) and OK B (preassembled), painted sheet steel, floor standing, for indoor use, rated Type 1 and 12.

### Notes:

- These component enclosures are intended for the installation of industrial electrical equipment where the complete assembly is approved for installation in non-hazardous locations in accordance with the Canadian Electrical Code Part I and the National Electrical Code.
- The full enclosure model codes/catalogue designations may be completed by suffixes indicating dimensions, mechanical details, and accessories that may be provided or supplied with the enclosures (see Attachment 2 of report for further details).
- Assembly and/or mounting and/or installation instructions/sheets are provided with each enclosure/accessory.

For details related to rating, size, configuration, etc. reference should be made to the CSA descriptive report.

**Certificate:** 2509560

**Project:** 2509560



**Master Contract:** 190952

**Date Issued:** May 21, 2012

### **APPLICABLE REQUIREMENTS**

#### Canadian Standards

CSA Standard C22.2 No 0	General Requirements - Canadian Electrical Code, Part II
CSA Standard C22.2 No 94.1	Enclosures for Electrical Equipment, Non-Environmental Considerations
CSA Standard C22.2 No 94.2	Enclosures for Electrical Equipment, Environmental Considerations

#### US Standards

UL Standard No 50	Enclosures for Electrical Equipment, Non-Environmental Considerations
UL Standard No 50E	Enclosures for Electrical Equipment, Environmental Considerations

### **MARKINGS**

All markings shall be in accordance with the requirements of the local regulatory authorities and related standards.

The following information is marked on an adhesive label located inside the door or enclosure and visible after installation: Submitter's name, trade name "QUADRITALIA" or the Master Contract "190952", the cCSAus monogram, and enclosure designation and rating "Type 1, 12".

Assembly and/or mounting and/or installation instructions are provided with each enclosure.



CSA INTERNATIONAL

## *Supplement to Certificate of Compliance*

**Certificate:** 2509560

**Master Contract:** 190952

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
2509560	May 21, 2012	OK K and OK B series enclosures. Original Certification.