



OK SERIES IP 65 TEST REPORT

Quadritalia declares that the above mentioned test was successfully carried out at



REPORT ref. No.: 350262700

STANDARD: EN 60529, DEGREES OF PROTECTION PROVIDED BY ENCLOSURES
(IPcode: IP 55 and IP 65).

DATE: 30/03/2012

LABORATORY: DEKRA testing and certification s.r.l., Osnago (LC)

NOTE: In order to obtain the IP 65 degree of protection, the customer should replace the bottom panel of the OK frame with the TTK latching kit, and by help of cable glands he can proceed with the installation. We inform you, that IP 65 is allowed for single door enclosures only. Maximum degree for double door enclosures is IP 55.

For any further comments or assistance please contact

Quadritalia s.r.l.
Via E. Mattei 6/10
36040 Brendola (VI)
www.quadritalia.com
info@quadritalia.com

QUADRITALIA s.r.l.